



## DECLARATION OF MANUFACTURER

**Stratos PICO-Z 20/...**  
**Stratos PICO-Z 25/...**  
**Stratos PICO-Z 30/...**

We, the manufacturer, declare under our sole responsibility that these glandless circulating pump types of the series,

(The serial number is marked on the product site plate)

in their delivered state are designed in accordance with generic health, safety and environmental requirements. On the delivered product associated hazards of different categories were identified:

- \_ **LOW VOLTAGE EQUIPMENT SAFETY**
- \_ **ELECTROMAGNETIC COMPATIBILITY**
- \_ **RISK OF PRESENCE OF HAZARDOUS SUBSTANCES (10 substances)**

Regarding hazardous substances, current legal obligations, valid for EEA (european economic area), are applied. Dependent on regulation specific exemptions might be valid.

Procedures and methods for limiting those risks from the above-mentioned hazards are strictly followed. These procedures and methods are defined and prescribed within international standards:

**IEC 60335-1:2010+A1:2013+A2:2016; IEC 60335-2-51:2019;**  
**IEC 61000-6-1:2016; IEC 61000-6-2:2016; IEC 61000-6-3:2020; IEC 61000-6-4:2018;**  
**IEC 63000:2016;**

Person authorized to compile the technical file is:

Dortmund,

H. HERCHENHEIN  
Senior Vice President - Group Quality & Qualification

Declaration n°2223646-rev01

WILO SE  
Group Quality  
Wilopark 1  
D-44263 Dortmund

**wilo**

Wilopark 1  
D-44263 Dortmund

PC As-Sh n°4258259-WW-rev01